

City of Cumming

Department of Utilities

Distribution and Collection Division



Manual of Technical Specifications & Construction Standard Details

For the City of Cumming

Water Distribution System

Within the Corporate City Limits and the City's Water and Sewer Service Area

This Document was Approved November 1994
Revised September 2005

Table of Contents

Page

SECTION I – Introduction	3
SECTION II – Abbreviations	4
SECTION III - Design Criteria Index	6
SECTION IV – Material Specification Index	13
SECTION V - Construction Index	23 - 24
SECTION VI - Standard Drawings of Typical Details Index	35 - End

NOTE: The September 2, 2005 revision to this document includes several requirements from the Georgia Environmental Protection Division (EPD). These revisions are italicized and underlined so that they can be quickly identified.

SECTION I: Introduction

The purpose of this Manual is to provide design criteria, material specifications, and installation procedures for water mains, valves, fire hydrants and water services for the City of Cumming's Water and Sewer Service Area (see map last page of this book). This Manual is divided into three main sections that cover design, material, and construction. Other sections provide standard construction drawings, and a listing of common abbreviations.

When this Manual imposes more restrictive standards than are required by any statute, ordinance, or regulation applicable within the City's Water and Sewer Service Area, the requirements of this Manual shall govern. When the provisions of any other statute, ordinance, or regulation are more restrictive than the provisions of this Manual, the provisions of the more restrictive regulation shall apply.

The requirements of this Manual are subject to change without notice.

SECTION II: Abbreviations

<u>Item:</u>	<u>Definition:</u>	<u>Web Address:</u>
AASHTO	American Association of State Highway and Transportation Officials	www.aashto.org
ANSI	American National Standards Institute	www.ansi.org
AO	Astro Optics Corporation (reflectors)	www.astrooptics.com
ASTM	American Society of Testing Materials	www.astm.org
AWWA	American Water Works Association	www.awwa.org
COCWS	City of Cumming Water System	www.cummingutilities.com
FCWS	Forsyth County Water System	www.forsythco.com
DOT	Georgia Department of Transportation	www.dot.state.ga.us
NFPA	National Fire Protection Association	www.nfpa.org
NSF	The Public Health and Safety Company	www.nsf.org
OSHA	Occupational Safety and Health Administration	www.osha.gov
UL	Underwriter's Laboratories, Inc.	www.ul.com
UPC	Georgia Utility Protection Center Call Before You Dig (800) 282-7411	www.gaupc.com
PSC	Public Service Commission	www.psc.state.ga.us
DIP	Ductile Iron Pipe	
GPM	Gallons Per Minute	
MJ	Mechanical Joint	
SJ	Slip Joint	
PJ	Pack Joint	
MSL	Mean Sea Level	

ppm	Parts Per Million or Milligrams Per Liter (mg/L)
PSI	Pounds Per Square Inch
PVC	Polyvinyl Chloride Pipe
f.i.p.	female (threaded) iron pipe
m.i.p.	male (threaded) iron pipe
c.t.s.	copper tubing size
ROW	Right-Of-Way for city, county, or state roadways
DOU	Department of Utilities (City of Cumming)
RPZ	Reduced Pressure Zone Backflow Preventer

SECTION III: Design Criteria Index

<u>Subject:</u>	<u>Page:</u>
1. WATER MAIN SIZE	7
2. WATER MAIN LOCATION	8
A. Within GA DOT Right-of-Way	8
B. Along City Roads	8
C. At Existing Culverts and Streams	8
D. Along County Roads	9
E. Water Main Cover	9
3. ROADWAY CROSSINGS	9
A. City/County Roads Under Control of GA DOT	9
B. Paved Streets	9
C. Unpaved Streets	9
4. FIRE HYDRANT SPACING	10
5. WATER VALVE SPACING	10
6. AIR RELEASE VALVES	11
7. LOCATION OF WATER SERVICES	12
8. STREAM, CREEK, RIVER, & OTHER WATER CROSSINGS	12

Section III: Design Criteria

Note: Developments requesting water service at elevations in excess of 1280 feet above Mean Sea Level (MSL) will be responsible for designing and constructing a pumping system which meets the approval of the City of Cumming Potable Water Booster Pumping Station Design Manual and the City Engineer.

1. WATER MAIN SIZE:

A. Type of Development:

The size of water mains within the City of Cumming's Water and Sewer Service Area shall be determined by the type of development being served and the quantity of water necessary for fire protection. The minimum water flow necessary for fire protection for various types of developments are shown below in Table 3-1:

Table 3-1 Minimum Water Flow Required For Fire Protection:

Residential	750 GPM	Test for 20 Minutes
Multi-Family, Patio Homes, and Developments with Greater than 3 Units Per Acres.	1000 GPM	Test for 20 Minutes
Shopping Centers	1500 GPM	Test for 30 Minutes
Motels, Light Industry	1500 GPM	Test for 30 Minutes
Heavy Industry	1500 GPM	Test for 45 Minutes

B. Minimum Residual PSI: A minimum residual pressure of 20 psi shall be used when determining water main sizes. City water storage tanks shall be assumed to be one-half full (elevation 1402 MSL).

C. City of Cumming Water Master Plan: All developers and all new developments shall meet the requirements of the most current edition of the ***City of Cumming Water Master Plan***.

D. Predevelopment Fire Flow Test: A predevelopment fire flow test must be conducted on the water main that will be used to supply water to the proposed development. If the fire flow test does not meet the City requirements, then system-wide upgrades and improvements must be made at the expense of the developer. No new development will be permitted if in the opinion of the City, the new development will negatively impact the water supply, fire flow, or pressure of an existing or future development or customer.

E. Final Plat On-Site Fire Flow Test: An as-built fire flow test must be conducted at each new fire hydrant, at the expense of the developer, before the City will sign off on the final plat. The water system must be completed before the City will accept the results from an as-built fire flow test. The as-built fire flow test reports on each hydrant must be submitted to the City along with the final plat.

F. Impact On Subsequent Developments: A new development shall not diminish the water supply, fire flow, or water pressure of an existing or future development or customer. The Director of Utilities will make the determination as to whether or not a new development will or will not diminish the water supply, fire flow, or water pressure of an existing or future development or customer.

2. WATER MAIN LOCATION:

NOTE: It shall be the policy of the City of Cumming to require developers to obtain, at their own expense, an easement located outside of the public right-of way, for all utilities that are to be installed along roadways. The purpose for this policy is to avoid unnecessary costs to the City that are associated with moving utilities for road-widening projects.

A. Within Georgia Department of Transportation Right-of-Way: For water mains or services that are to be located within the Georgia DOT right-of-way, an approved permit which meets the requirements of the Georgia DOT, shall be obtained prior to installation of the line. The developer shall provide to the City, all supporting maps, drawings, and details necessary to complete the Georgia DOT permit application. The City shall submit the application to the Georgia DOT for approval and will receive the permit from the State. The utility contractor will be responsible for posting the necessary permit documentation at the job site.

B. Along City of Cumming Roads:

1. Water mains that are to be located along existing City roads shall be located as far off the edge of the roadways as practicable. If the water main is to be covered by concrete (sidewalks, driveways, etc., the water main shall be Ductile Iron Pipe (DIP).

2. When water mains are to be located along new streets, they shall be located a minimum of five (5) feet behind the back of the curb. If the water main is to be covered by concrete (sidewalks, driveways, etc., the water main must be Ductile Iron Pipe (DIP).

C. At Existing Culverts and Streams:

Water mains shall be deflected around all existing cross drains and headwalls. When the water main crosses a stream, a minimum of 3-foot cover shall be provided (see drawing W-58). Water mains shall not be placed over existing cross drains unless approved

by the Department of Utilities. When water mains are placed over cross drains or around catch basins (see drawing W-47), a minimum of three joints of ductile iron pipe shall be used.

D. Along County Roads:

When water mains are to be located along existing County roads, the location shall be as far off the edge of the roadway as practicable, utilizing the back five feet of right-of-way, whenever possible. Any utility work that is proposed within the right-of-way of a County road will require a Utility Permit from the Forsyth County Department of Engineering. The utility contractor will be responsible for obtaining such permit.

E. Water Main Cover:

Water mains 6-inches through 10-inches in diameter shall be installed with a minimum-cover of 3-feet. Water mains that are 12-inches in diameter and larger shall be installed with a minimum-cover of 4-feet. In rock cuts, a minimum of 6-inches of earth cushion below and along the side of the mains shall be provided.

3. ROADWAY CROSSINGS:

A. City/County Streets Under Control of Georgia Department of Transportation:

When water mains are to cross roads under the control of the Georgia DOT, an approved permit which meets the requirements of the Georgia DOT shall be completed and approved by Georgia DOT prior to installation. The City of Cumming shall make application for all Georgia DOT Utility Permits. The developer shall provide all required data for the permit to the City including but not limited to, maps, surveys, legal descriptions, and other pertinent data.

B. Paved Streets:

1. Water mains crossing existing paved City/County streets shall be installed in steel casing. For internal subdivision roads (non-thoroughfares), the size casing for water main shall be 6-inches larger in diameter than the nominal diameter of the water main. For all other roads, the size casing for water main shall be 8-inches larger in diameter than the nominal diameter of the water main. Any deviation must be approved by the DOU.

2. The open cutting of any paved street or driveway within the City of Cumming's Service Area is prohibited, unless approved by the DOU.

C. Unpaved Streets:

Water mains crossing existing unpaved City or County streets may be installed by the open-cut method, if approved by the DOU. Water-main street-crossings in new developments are required to be ductile iron pipe. No steel casing is required if the water main is installed prior to street paving.

4. FIRE HYDRANT SPACING:

A. Maximum Hose Lay:

The distance between fire hydrants shall be such that a maximum hose lay of 500 feet will reach all portions of the buildings which are to be serviced. Hydrant spacing requirements for various types of developments are listed below in Table 3-2:

Table 3-2 Fire Hydrant Spacing:

Note: a maximum hose lay of 500 ft for residential developments and 300 ft for commercial may be more restrictive than the City's maximum allowable distance between hydrants. In any case, the more restrictive of the two shall apply.

Type of Development	Distance Between Hydrants
Residential	1,000 FEET
Multi-Family	500 FEET
Shopping Centers	300 FEET
Motels, Light Industry	400 FEET
Heavy Industry	300 FEET

5. WATER VALVE SPACING:

A. The type of valve required for a given water-main size is shown in Table 3-3 below:

Table 3-3 Water Valve Type Required Given The Water Main Size

Water Main Size	Water Valve Type
6, 8, & 10 - Inch	Gate Valve
12-Inch and Larger	Butterfly Valve

B. Valves shall be located such that minimal sections of the water distribution system would be taken out of service during repair work.

C. When a water line branches off from the main, a valve shall be placed at the branch of the tee.

D. Valves are to be placed at all intersections of water mains. Valves shall be located at not more than 500-foot intervals in commercial districts and at not more than one block or 800-ft intervals in other districts. Where systems serve widely scattered customers, the valve spacing should not exceed 2,000 feet. See Drawing No. W-1 for guidance in placing valves in subdivisions.

E. Valves shall be provided at both ends of water crossings (creek, river, lake, etc. crossings) so that the section can be isolated for testing or repair (valves shall be easily accessible and not subject to flooding); the valve closest to the supply source shall be in a manhole.

F. On a one-way feed water main, which has branch lines from the main, main-line valves shall be placed at each branch of the tee. The valves shall be placed on the run of the tee which is furthest from the water supply source.

G. When a water main is looped, or there is a possibility that it will be looped, a valve shall be placed on each run and branch of all tees.

H. A valve shall be placed at the dead-end of each water main.

I. Refer to Standard Drawings for typical valve placement details. (Drawing Nos. W-1, W-8, W-9, and W-23)

6. AIR RELEASE VALVES:

A. At high points in water mains where air can accumulate, provisions shall be made to remove the air by means of hydrants or air relief valves. Automatic air relief valves shall not be used in areas where flooding of the manhole or chamber may occur.

7. LOCATION OF WATER SERVICES:

A. Water service lines for residential areas shall be a minimum of 1-inch in size (type "K" soft copper tubing) from the double-strap saddle up to the ball valve. From the ball valve (which is 18-24-inches below grade) up to the meter, the residential service line shall be ¾-inch, type "K" soft copper tubing. Water meters for residential areas shall be a minimum of three quarter (3/4) inch. (See Drawings W-42 and W-61).

B. Required water service sizes and water meter sizes for businesses and other commercial establishments shall be as required by the City of Cumming.

C. Service connections to the main line shall incorporate double-strap tapping saddles. Direct taps to the water main will not be allowed.

D. Water service lines which cross paved streets shall not be installed by the open-cut method. All water service lines shall be installed by boring under all paved streets. Steel casings are not required for bored service lines. In subdivisions, long side service shall be cased in PVC pipe. The casing shall be installed from back-of-curb to back-of-curb (See Drawing W-43).

E. Water service lines shall not be installed by the open-cut method across unpaved roadways, unless permission is given, in writing, for the permitting authority (City, County, or State road departments).

F. A minimum of 3-feet of cover shall be provided for bored water service lines. The minimum cover at the water meter box shall be fourteen (14) inches.

G. Water meter and boxes shall be installed at the right-of-way line of the roadway, unless the proposed installation is in a more recent development. More recent developments have curbed streets and the water-main is located five (5) feet behind the curb. Therefore, the location of the water-meter and meter-boxes in more recent developments shall be at the curb. In addition, the location of new water meters and meter boxes shall be consistent with the existing installations in the immediate are. THE STREET CURB SHALL BE MARKED WITH A SAW-CUT "W" AND THE "W" SHALL BE PAINTED BLUE AT EACH METER BOX LOCATION.

H. Refer to the Standard Drawings for typical water service details. (Drawing Nos. W-2, w-23, W-41, W-42, W-44, W-45, W-46, W-47, W-59, W-60, W-61 W-62 and W-63)

8. CREEK, RIVER, STREAM AND OTHER WATER CROSSINGS:

A. Valves shall be provided at both ends of water crossings so that the section can be isolated for testing or repair (valves shall be easily accessible and not subject to flooding); the valve closest to the supply source shall be in a manhole.

SECTION IV: Material Specification Index

<u>Subject:</u>	<u>Page:</u>
1 MATERIAL AND WORKMANSHIP	14
2. WATER MAINS	14
A. Joints	15
B. Coating	15
C. Casing Pipe	15
3. SERVICE LINES	16
4. FITTINGS	16
5. VALVES	17
A. Gate Valves	17
B. Butterfly Valves	17
C. Tapping Valves	17
D. Valve Markers	17
E. Valve Boxes	17
F. Valve Pad	18
6. FIRE HYDRANTS	18
7. TAPPING SADDLES	18
8. COUPLINGS	19
9. BRASS FITTINGS	20
A. Curb Stops	20
B. Corporation Stops	20
C. Adapters	20
10. WATER METERS	20
A. Service Line Meters	20
B. Master Meters (and Other Large Meters)	20
11. METER BOXES FOR 3/4 INCH WATER SERVICE	21
A. Composition - Metal	21
B. Configuration of Inlet and Outlet	21
12. BACKFLOW PREVENTERS	21

SECTION IV: Material Specification

1. MATERIAL AND WORKMANSHIP:

A. Furnish materials which are new, and unused, or if not particularized herein, which are the best of their respective kind, free of defects and imperfections, and suitable for the service intended.

B. Provide workmanship which is first-class in every respect. Have installation performed by workmen thoroughly experienced in such work. A neat and workmanlike appearance in the finished work will be required.

2. WATER MAINS:

1. All ductile iron pipe (DIP) shall conform to the latest requirements of AWWA C151. Ductile iron pipe material shall have a minimum tensile strength of 60,000 psi, a minimum yield-strength of 42,000 psi, and a minimum elongation of 10 percent.

2. All polyvinyl chloride (PVC) pipe shall meet the latest requirements of AWWA C900. PVC 1120 pressure pipe shall be made from Class 12454-A or Class 12454-B material conforming to ASTM D1784.

3. As a minimum, based on hydrostatic pressures at storage tank overflow elevation 1420, the following minimum pipe classes, listed below in Table 4-1, shall be used for ductile iron pipe and polyvinyl chloride pipe.

Table 4-1 Pipe Classification:

Elevation	6-Inch and 8-Inch	10-Inch thru 24-Inch
960 and above	Ductile Iron-Class 50 or Pressure Class 350; PVC-DR 14, Class 200	Ductile Iron-Class 50 or Pressure Class 350
Below 960	Ductile Iron-Class 51 or Pressure Class 350	Ductile Iron-Class 51 or Pressure Class 350

The above stated pressure classes are suitable for normal depths of cover. For other conditions, the pipe shall be designed in accordance with standard engineering practices, to withstand the expected live and dead loads.

4. When PVC pipe is used for water mains, **detector wire shall be used**. Follow procedures on Drawing No. W-10. In general, a minimum of two turns around each joint

of PVC is required. The wire shall be No. 12 solid copper wire and shall be stripped and connected to a tee-bolt on each side of all fittings and valves. A looped wire shall also be stripped and connected to the same tee-bolt as the underground locate wire. This looped “locator connection wire” shall be extended up the valve box and terminate at the lid of the valve box. This “locate connection wire” will provide a positive-connection for the City’s locate device so that an electrical current can be placed on the underground locate wire. The electrical current will help the City determine the absolute location of the PVC water main.

A. Joints:

1. Joints for ductile iron pipe shall be mechanical joint or push-on joint in accordance with AWWA C111 (latest revision).
2. All joints for PVC pipe shall be made with elastomeric gaskets. Bell-end pipe using elastomeric gaskets shall meet the requirements of ASTM D2122. Elastomeric gasket couplings shall meet the requirements of AWWA C900 (latest revision).
3. Solvent-cemented joints are not allowed for buried pipes.

B. Coating: Ductile iron pipe shall be lined with an approved cement lining sealed with an approved bituminous seal coat in accordance with AWWA C104 (latest revision). A standard pipe outside coating shall be used in accordance with AWWA C108 (latest revision).

C. Casing Pipe: Jacked casing pipe shall be a smooth steel pipe with a minimum tensile strength of 35,000 psi, or as approved by Georgia DOT. The minimum wall thickness shall be as indicated in the Table 4-2 below.

Table 4-2 Minimum Wall Thickness of Casing Pipe

Nominal Diameter	Nominal Thickness
in Inches	in Inches
Under 14	0.188
14	0.219
16	0.219
18	0.250
20	0.281
22	0.312
24	0.344
26	0.375
28	0.406
30	0.406
32	0.438
34	0.469
36	0.469
42	0.500
48	0.625
54	0.750

3. SERVICE LINES:

A. Both ¾-inch and 1-inch water service lines shall be type “K” soft copper tubing. Copper tubing shall be Type K, DHP soft or hard copper pipe conforming to ASTM B88.

B. All 2-inch water service lines shall be Type K, DHP soft or hard copper pipe, and shall conform to ASTM B88.

4. FITTINGS:

A. Cast Iron and Ductile Iron Fittings: Cast and ductile iron fittings for 6-inch pipe and larger shall conform to ASA 21.10 and AWWA C110, or AWWA C153 (latest revision). Fittings shall have minimum classification of Class 350 type of joints, and fittings shall be mechanical joints only. All mechanical joint fittings shall include accessories. All fittings shall be cement lined with tar coated outside.

B. Fittings: Plastic, or galvanized, fittings on any size pipe will not be allowed.

5. **VALVES:**

A. **Gate Valves:**

1. Gate valves are required for all 6-inch through 10-inch water mains.
2. Gate valves for 6, 8, and 10-inch water mains shall conform to the latest requirement of AWWA C500. Gate valves shall be designed for 200 psi working pressure and 400 psi hydrostatic test pressure. Gate valves will be of the iron body, bronze mounted, resilient seat type and shall have a non-rising bronze stem, and shall be wrench operated. All valves shall open by turning counterclockwise. Operating nuts shall be standard 2-inches square. Where required, suitable extension stem guides shall be provided. Gate valves will be furnished with mechanical joint ends except 2-inch service valves which shall be supplied with f.i.p. ends. Valves shall be Mueller, M and H, American or equivalent. All proposed equivalent brands must be approved by the City of Cumming Utility Inspector.

B. **Butterfly Valves:** Butterfly valves will be required for water mains 12-inches in size and larger in size. Butterfly valves shall have a cast iron valve body for buried service, of the stainless steel-to rubber seated, tight closing type, suitable for two-way flow, Class 150B, with manual operators sized for actual line pressure and velocities, and shall have 2-inch square operating nut and extension stems and guides as required. The valves shall open in the counterclockwise direction as with the gate valves. Butterfly valves shall comply with the latest requirements of AWWA C504. Butterfly valves shall be Henry Pratt, BIF, Allis Chalmers, or approved equal.

C. **Tapping Valves:** Tapping sleeves shall be properly sized to fit the existing pipe and shall be of the fabricated s.s. with wrap-around gasket type with ends suitable for connection into the pipe line into which it will be installed. The valves furnished with the sleeves shall conform to the requirements for gate valves, except for modifications required to permit the use of full size cutters through the valves. The outlet of the valves shall be mechanical joint for joining with the water mains. All 2-inch tapping valves shall be furnished with f.i.p. ends. All proposed brands must be approved by the City of Cumming Utility Inspector.

D. **Valve Markers:** Valve markers shall be furnished and installed with each valve installed, with exception of fire hydrant valves. The markers shall be of Class A concrete Georgia DOT (highway specifications) four (4) inches square by five (5) feet long, same construction as that of highway right-of-way marker, with the letter "V" firmly made into the marker six (6) inches below the top with a 1-1/4 inch brass plug one (1) inch below the letter "V", which shall be imprinted with the distance between the valve and marker. The markers shall be set opposite the valves in such a location as they would not be destroyed by traffic. The top of the marker should be set about eighteen (18) inches above ground. The street curb shall also be marked with a saw-cut letter "V" and the "V" shall be painted blue.

E. Valve Boxes: Valve boxes and covers shall be provided with all valves, shall be of the adjustable slide type, of the length required, and installed as shown on Drawings W-5 and W-6. The shaft will be 5-1/2 inch diameter with the base to be a minimum of 8-3/4 inch diameter by 9-inches height inside. The covers for valve boxes shall be of the stay-put or drop type, with the word "Water" cast on top in raised letters. Base size and extension piece shall be as required for each individual size of valve and depth.

F. Valve Pad: Valve Pads shall be furnished and installed with each valve installed. The pads shall be of the round concrete type.

6. FIRE HYDRANTS:

A. Fire hydrants shall conform to the latest requirements of AWWA C502, be the traffic type, dry top, 5-1/4 inch valve opening with O-ring seals, three-way only. The three-way hydrants are to have two, 2-1/2-inch NST hose nozzles and one, 4-1/2-inch NST hose nozzle. The main valve shall be rubber faced, shall seat against a bronze seat and shall open against pressure. Hydrants shall range from 3-foot to 5-foot bury with 6-inch mechanical joint inlet connection. Operating nuts shall be pentagon (1-1/2 inch point to flat) and shall open by turning counterclockwise. All fire hydrant laterals shall have 6-inch gate valves and valve boxes. Fire hydrants shall be as manufactured by Clow or M & H.

B. All fire hydrants shall be painted in accordance with AWWA C502, Section 2.22 and Section 4.5. The color shall be silver and red (silver with a red top). Use Sanders Paint, Product No. A400 Aluminum, Metal Bright, or equal.

C. All fire hydrants shall be connected to the water main with a 6-inch ductile iron lead. **PVC pipe will not be allowed for fire hydrant leads.**

7. TAPPING SADDLES:

A. All service connections to the water main shall use 1-inch CC Tap Thread Saddles.

B. 3-inch and 4-inch PVC pipe shall use Ford Style (S70) Brass Saddle with 1" CC Tap Threads. Connections of 2-inch copper shall be accomplished with a pack joint x 1-inch f.i.p. tee.

C. 6-inch through 30-inch PVC and DI Class 50 or 350 shall use double strap Smith Blair Style (313) or Ford Style (202) with 1-inch CC Tap Threaded Saddles.

Table 4-3 Part Numbers Tapping Saddles:

Smith Blair	S.B. Part Number	Ford	Ford Part Number
4 X 1	313-056309-000	4 X 1	F202-526-CC4
4 X 2	313-048014-000	4 X 2	F202-526-IP7
6 X 1	313-076009-000	6 X 1	F202-760-CC4
6 X 2	313-076014-000	6 X 2	F202-760-IP7
8 X 1	313-101009-000	8 X 1	F202-979-CC4
8 X 2	313-101014-000	8 X 2	F202-979-IP7
10 X 1	313-121209-000	10 X 1	F202-1212-CC4
10 X 2	313-121214-000	10 X 2	F202-1212-IP7
12 X 1	313-143209-000	12 X 1	F202-1438-CC4
12 X 2	313-143214-000	12 X 2	F202-1438-IP7
16 X 1	313-188809-000	16 X 1	F202-1840-CC4
16 X 2	313-188814-000	16 X 2	F202-1840-IP7
18 X 1	313-195009-000	18 X 1	F202-2050-CC4
18 X 2	313-195014-000	18 X 2	F202-2050-IP7
24 X 1	313-258009-000	24 X 1	F202-2650-CC4
24 X 2	313-258014-000	10 X 1	F202-2650-IP7
30 X 1	-----	30 X 1	F202-3274-CC4
30 X 2	-----	30 X 2	F202-3274-IP7

8. COUPLINGS:

A. Repair, transition and bolted couplings to be used for water line installation shall be as shown on Table 4-4.

Table 4-4 Pipe Couplings:

Water Line Size	Specification	Coupling	
3/4 "	Type "K" Soft Copper	Ford brass "Pack- Joint" or A.Y. McDonald Brass "Mac-Pak"	
1 "	Type "K" Soft Copper	Ford brass "Pack- Joint" or A.Y. McDonald Brass "Mac-Pak"	
2"	Type "K" Soft & Hard Copper	Ford brass "Pack- Joint" or A.Y. McDonald Brass "Mac-Pak"	
6"	C900 Ductile iron pipe	M.J. Ductile Iron Solid Sleeve	
8"	C900 Ductile iron pipe	M.J. Ductile Iron Solid Sleeve	
10"	C900 Ductile iron pipe	M.J. Ductile Iron Solid Sleeve	
12" And Larger	C900 Ductile iron pipe	M.J. Ductile Iron Solid Sleeve	

9. BRASS FITTINGS:

A. Curb Stops:

1. Curb stops for copper service lines shall be Ford 90° c.t.s. pack-joint x meter swivel or equivalent as approved by the City of Cumming Utility Inspector.

B. Corporation Stops:

1. Corporation stops for copper service outlets shall be Ford model F-1000-4 c.t.s. pack-joint or equivalent as approved by the City of Cumming Utility Inspector.

C. Adapters:

1. Copper female iron pipe adapters shall be Ford c.t.s. pack joint x f.i.p. or equivalent as approved by the City of Cumming Utility Inspector.

2. Copper by copper unions shall be Ford c.t.s. x c.t.s. pack joint or equivalent. All proposed equivalent brands must be approved by the City of Cumming Utility Inspector.

3. Copper by male iron pipe adapters shall be Ford shall be Ford c.t.s. pack joint x m.i.p. or equivalent. All proposed equivalent brands must be approved by the City of Cumming Utility Inspector.

10. WATER METERS:

A: Service Line Meters Water meters for normal residential service shall be three-quarter (3/4)-inch in size. Water services requiring meters up to and including 2-inch size shall be installed by the City of Cumming.

B: Master Meters (And Other Large Meters): Water meters 3-inches and larger, shall be compound type meters. These meters shall have a cast bronze main-case, measure in gallons per minute, and have a hermetically sealed register with a magnetic coupling drive, as manufactured by Neptune. The general arrangement of the meter pit shall include locking by-pass lines, valves, double check valves, strainers, etc., as may be required by the City's Engineer for the specific application. There are two options available for water meters larger than 2- inches:

- **Option 1** – The owner or contractor may purchase and install a meter that meets the specifications of the City of Cumming. A fee of eight dollars per gallon per minute (\$8.00 per gpm) must be paid to the City of Cumming before the installation of the meter will be permitted. (Note: this rate is

subject to change without notice. Please contact the Utility Billing Department for a current rate).

- **Option 2** – The City of Cumming will purchase and install the meter. The City will then charge the owner or contractor the eight dollars per gallon per minute (\$8.00 per gpm) fee plus the cost of materials and labor. (Note: this rate is subject to change without notice. Please contact the Utility Billing Department for a current rate).

11. METER BOXES FOR 3/4 INCH WATER SERVICE:

- A.** Typical residential water meter boxes shall be composed of cast iron and shall be approximately 14-1/2-inches long with an approximate 7 1/8-inch wide oval top opening. The meter box shall be approximately 11-inches deep. A cast iron locking lid shall be provided with all meter boxes. Each lid shall be supplied with a hole with the following diameter: 1 27/32 inches (see Drawing W-56 and W-57). Accepted brands include Ford cast iron long yoke-boxes and A.Y. McDonald cast iron long-boxes.
- B.** Meter box inlets shall be configured as follows:
1. 3/4-inch cts angle locking type ball valve with Ford Pack Joint or McDonald Mac-Pac compression fittings for dual meter service lines.
 2. 3/4-inch angle locking-type ball valve with Ford Pack Joint or McDonald Mac-Pac compression fittings for single meter service lines.
- NOTE:** Dual meter service lines use a ball valve and “Y” fitting with 1-inch inlet X two 3/4-inch outlets. All single meters use a 1” X 3/4” adapter in place of the “Y” fitting.

Meter box outlets shall be configured as follows:

1. All outlets will be 3/4-inch iron pipe threads
2. A 3/4-inch brass nipple and 3/4-inch brass ball valve are to be installed at the outlet of the meter box.

12. BACKFLOW PREVENTER:

All residential services shall have backflow preventers installed in series with the water meter in the meter box. The City of Cumming will install the backflow preventer with each water meter for sizes 3/4-inch – 2-inch. For sizes 3/4-inch through 1-inch, the backflow preventer shall be Watts No. 7 Residential Dual Check Backflow Preventer with bronze body, or approved equal. For sizes larger than 1-inch, or for services other than residential, backflow preventer shall be designed for the specific application and shall be approved by the City of Cumming Utility Inspector.

The City of Cumming is responsible for protecting the public potable water distribution system from contamination or pollution due to the backflow of contaminants or pollutants through a water service connection. A cross-connection is a connection or

potential connection between any part of a potable water system and any other environment containing other substances in a manner that, under any circumstances would allow such substances to enter the potable water system. Other substances may be gases, liquids, or solids, such as chemicals, waste products, steam, water from other sources (potable or nonpotable), or any matter that may change the color or add odor to the water.

In certain cases, the City will require a reduced pressure backflow prevention assembly. The City will dictate when these type backflow preveters are to be installed. Examples of businesses that will require an RPZ include but are not limited to mortuaries, industrial facilities, wastewater pumping systems, chemical plants, wastewater treatment facilities, commercial facilities, agricultural facilities, etc. An approved RPZ and "hotbox" will be required so that the backflow preventer is elevated above the ground level and heated during freezing weather. Elevating an RPZ is required so that the appropriate "air-gap" is provided at all times. An RPZ below grade could become submerged in water and thereby be rendered inoperable and ineffective. See Drawing W-67 for details on the required configuration for a RPZ and hotbox. Please note that the hotbox must be supplied with electrical power and a heating element.

SECTION V: Construction Index

<u>Subject:</u>	<u>Page:</u>
1. EARTH EXCAVATION	25
A. Clearing and Grubbing	25
B. Care of Surface Materials	25
C. Excavation Methods	25
D. Disposal of Material	25
E. Borrow	25
2. ROCK EXCAVATION	26
A. Blasting	26
B. Disposal	26
3. SUBSURFACE OBSTRUCTIONS	26
A. General	26
B. Existing Underground Utilities and Obstructions	26
C. Relocation of Services	26
4. INTERRUPTION OF WATER SERVICE DURING CONSTRUCTION	27
5. PIPE LINE INSTALLATION	27
A. Trench Excavation	27
B. Material Handling	27
C. Bedding in Earth Trenches	27
D. Bedding in Rock Trenches	27
E. Distance From Existing or Proposed Sanitary Sewer	
6. BACKFILL	28
A. Backfill Under Paved Roadways	28
B. Backfill Under Unpaved Roadways	28
C. Backfill in Unpaved Areas	28
7. ROAD CROSSINGS	28
A. Street Cuts	28
B. Tunneling	28
C. Boring and Casing	29
8. DRIVEWAY CROSSINGS	29

9.	REPLACEMENT OF PAVEMENT AND STRUCTURES	29
	A. Asphalt Pavement	29
	B. Gravel Roadway Replacement	30
	C. Driveway Replacement	30
	D. Curb and Gutter Replacement	30
	E. Sidewalk Replacement	30
10.	BLOCKING FOR PRESSURE LINES	31
11.	FIRE HYDRANT INSTALLATION	31
12.	VALVE INSTALLATION	31
13.	WATER SERVICE LINE INSTALLATION	32
14.	PRESSURE AND LEAKAGE TESTS	32
	A. Pressure Test	32
	B. Leakage Test	32
15.	FLUSHING AND DISINFECTION	33
16.	AS-BUILT DRAWINGS	34

SECTION V Construction:

1. EARTH EXCAVATION:

A. Clearing and Grubbing: Areas for water line installation must be cleared and grubbed. All trees, stumps, brush, paving and other waste material must be removed from the site. No large trees located within the right-of-ways shall be removed without the approval of the City of Cumming.

B. Care of Surface Materials:

1. No trees or shrubs will be removed without the approval of the Owner and the City of Cumming. All trees, shrubs, fences, mail boxes or other personal property damaged or removed, shall be replaced.

2. Upon completion of the water line installation, all disturbed areas shall be seeded, fertilized and mulched with hay. All seeding shall be approved by the City of Cumming. Care must be taken to ensure proper drainage of the area as approved by the City.

C. Excavation Methods:

1. When excavation is in open cut, the sides of the trench should be sloped as necessary to maintain stability.

2. When sheeting is used, it shall be left in place until the backfilling is completed no less than twelve (12) inches above the top of the pipe. Then, the upper section of the sheeting may be removed. When the removal of sheeting endangers adjoining improvements, it will be left in place.

3. All water shall be removed from trenches by pumping, bailing or draining. Groundwater encountered in the excavation shall be depressed to an elevation twelve (12) inches below the bottom of the excavation before pipe-laying may continue.

D. Disposal of Material: All excess material and waste material should be disposed of immediately after the backfill operation has been completed.

E. Borrow: When excavated material cannot be used as a suitable backfill, an approved borrow material shall be used.

2. ROCK EXCAVATION:

A. Blasting: When blasting is necessary for rock excavation, the explosives must be used, handled, and stored as prescribed by the laws and regulations of the State of Georgia and all local laws applicable. The blasting work must be done by an experienced person. Any damage occurring to persons or personal property due to blasting will be repaired at the Contractor's expense.

B. Disposal: All rock larger than two (2) inches in diameter must be removed from the site and disposed of in a manner approved by the City of Cumming.

3. SUBSURFACE OBSTRUCTIONS:

A. General: It is the responsibility of the Contractor to locate and protect all underground utilities and structures. No utility is to be moved or disturbed without the approval of that utility company. Any damage caused by water line installation to any utility or structure shall be immediately reported to the City, and repaired at the Contractor's expense. The Contractor shall be responsible for any expenses incurred as a result of damage to existing utilities. Contractors must adhere to all state laws and the rules of the Georgia Utility Protection Center (UPC).

B. Existing Underground Utilities and Obstructions: Where known or unforeseen underground utilities or obstructions are encountered, minimum depth of cover, or the location and alignment may be changed, upon written approval of the City of Cumming.

C. Relocation of Services: The City of Cumming shall have the right to determine the services which are to remain in place and the services which shall be relocated as best suits conditions as found, in accordance with the following:

1. Services to Remain in Place: Where the City of Cumming determines the services shall remain in place, minimum specified depths of cover for the pipe lines may be changed to avoid interference with such services.

2. Services to be Relocated: Where the City of Cumming determines the services shall be relocated, the Utility will make the necessary changes at its expense.

4. INTERRUPTION OF WATER SERVICE DURING CONSTRUCTION:

NOTE: No interruption of water service for connections will be allowed without the permission and supervision of the City of Cumming. Proposed interruptions to water service shall be coordinated with the City. Customer notification prior to water service interruption is mandatory and must be given at least 24 hours prior to the interruption. Contractors shall make every effort to minimize the impact of the interruption. For example, when possible, thrust blocks should be poured in advance of the interruption so that concrete curing time is not a factor.

5. PIPELINE INSTALLATION:

A. Trench Excavation: Trenches shall be excavated to their required depth and width to provide for an efficient and safe working environment.

B. Material Handling: Proper and suitable tools and equipment for the safe and convenient handling and laying of pipe shall be used, and great care shall be taken to prevent the pipe from being damaged, particularly the cement lining on the interior of the ductile iron pipe. All pipe shall be carefully examined for cracks and other defects; if any pipe or other casting is discovered to be cracked, broken, or defective after being laid, it shall be removed and replaced with new material. All pipe and fittings shall be thoroughly cleaned before being laid, and shall be kept clean until completion of the work.

C. Bedding in Earth Trenches: Where pipe is laid in earth excavated trenches, the bottom of such trenches shall be fine graded to a true line, the pipe lines shall not be laid on loose rock or other hard material. Over excavation in the bottom of trenches shall be filled to grade with compacted graded aggregate or suitable earth material.

D. Bedding in Rock Trenches: Where pipe is laid in rock trenches, it must be bedded with a minimum of six (6) inches of compacted graded aggregate. The trench must be backfilled with select backfill material to a level at least one (1) foot over the top of the pipe.

E. Distance From Existing or Proposed Sanitary Sewer Lines: Water mains shall be laid at least ten (10) feet horizontally from any existing or proposed sanitary sewer, storm sewer or sewer manhole. The distance shall be measured edge-to-edge. When local conditions prevent a horizontal separation of 10 feet, the water main may be laid closer to a sewer (on a case-by-case basis) provided the water main is laid in a separate trench or on an undisturbed earth shelf located on one side of the sewer at such an elevation that the bottom of the water main is at least 18 inches above the top of the sewer. It is advised that the sewer be constructed of materials and with joints that are equivalent to water main standards of construction and be pressure tested to assure water-tightness prior to backfilling.

6. BACKFILL:

A. Backfill Under Paved Roadways: Backfill under permanent concrete or bituminous pavement shall be compacted graded aggregate. Compaction shall be 100% of the dry rodded unit weight in accordance with AASHTO T99. Compaction shall be accomplished by using a hand vibratory compactor.

B. Backfill Under Unpaved Roadways: Backfill under gravel surfaced roadways and surface treated type bituminous roadways shall be backfilled using select material placed in six (6) inch layers thoroughly compacted for the full depth and width of the trench. Compaction shall be to 95% as determined by AASHTO T99. Compaction shall be accomplished by using a hand vibratory compactor.

C. Backfill in Unpaved Areas:

1. Backfill in unpaved areas shall be select material compacted to 90% as determined by AASHTO T99, or compatible with the surrounding area.

2. The type bedding to be used in water line installation shall be determined by design pressures and depth of cover. For a design pressure of 150 psi and for depths up to 8 feet, Type III bedding shall be used. Refer to the Standard Drawings for typical details. (Drawing No.W-3)

7. ROAD CROSSINGS:

A. Street Cuts: When open street cuts have been approved by the City of Cumming, the following rules must be adhered to:

1. Construction work allowed between 9 A.M. and 4 P.M. on weekdays only, unless otherwise approved by the City of Cumming.

2. One (1) lane of traffic must be open at all times.

3. Traffic control devices, as required by Georgia DOT, must be used to direct traffic.

4. Repair of the street cut shall be in accordance with the Standard Drawing.

5. If an open ditch is left unattended for any length of time, a 3/4 inch steel plate must be used to cover the ditch.

B. Tunneling: When tunneling under roadways, the methods used must be in accordance with the rules and regulations of the Georgia DOT.

C. Boring and Casing: Water lines crossing all paved streets shall be installed by boring and casing unless otherwise approved by the City of Cumming. The boring and casing methods used must be in accordance with requirements of the Georgia DOT.

Note: *Whenever a state route or heavily traveled off-system road or a rail-road is crossed, the agency that has jurisdiction over the road or the rail-road must be notified, prior to the installation of the mains. At the crossing, a steel casing with sufficient diameter must be jacked and bored to accommodate the carrier pipe. Any free boring at low traffic city streets and county roads must conform to the applicable local and/or state requirements.*

8. DRIVEWAY CROSSINGS:

A. Water lines must be bored under existing asphalt or concrete driveways. Paved driveways shall not be open-cut without prior permission of the owner and the City.

B. When water lines are installed by the open-cut method, smooth, even saw cuts shall be made across the paved area before any material is removed. Ripping up pavement using a backhoe, without saw cuts, will not be allowed.

C. When water lines are bored under driveways, a minimum of three (3) foot cover is required. Steel casing under driveways is not required.

9. REPLACEMENT OF PAVEMENT AND STRUCTURES:

A. Asphalt Pavement:

1. Asphalt pavement replacement for water lines installed under paved roadway surfaces shall be type "A" as detailed in the Standard Drawings (Drawing No. W-48). Base course shall be placed and compacted immediately after backfilling and made level with adjacent existing paving.

2. If compaction is sufficient after the base course is placed, the base course shall be removed to a sufficient depth to provide no less than two (2) inches of wearing course level with adjacent grade. A bituminous priming treatment shall be applied to the base course prior to the placing of the two (2) inch type "E", or "F" surface course.

3. Asphalt pavement replacement for transverse street cuts shall be of type "B" pavement, as detailed in the Standard Drawings. (Drawing No. W-48)

B. Gravel Roadway Replacement: The material used in restoring gravel roadways shall be the same as those which composed the wearing and base courses of the existing roadway. As a minimum, roadway material shall be equal to crusher run stone conforming to the Georgia DOT Standard Specification.

C. Driveway Replacement:

1. Concrete driveways shall be constructed to the thickness of the adjoining wearing surface and base course shall be constructed of similar materials and dimensions as the original base course. As a minimum, 3,000 psi concrete shall be used as a wearing course, as detailed in the Standard Drawings. (Drawing No. W-50)

2. Asphalt driveways shall be repaired as detailed in the Standard Drawings. (Drawing No. W-50)

3. Gravel driveways shall be restored to their original condition and dimensions using materials similar to those already in place. As a minimum, gravel driveways shall be six (6) inches of No. 57 crushed stone or graded aggregated base (G.A.B.), conforming to the Georgia DOT Standard Specifications as detailed in the Standard Drawings. (Drawing No. W-50)

D. Curb and Gutter Replacement:

1. All curbs and combination curbs and gutters, which have been removed or disturbed in the progress of the work, shall be replaced at the Contractor's expense. Curbing shall be made to conform accurately in size, line, grade and materials with that adjoining. In restoring curbs, the subsoil and foundation material shall be well compacted so as to prevent any settlement. (Drawing No. W-4)

2. All granite curb shall be restored with material equal to that already in place.

3. All concrete curbing shall have minimum 28 days compressive strength of 2,500 psi.

E. Sidewalk Replacement:

1. All sidewalks, disturbed in the process of the work, shall be constructed to the same grade, dimensions and materials as were originally in place.

2. Where necessary to cut a sidewalk, entire slabs or squares shall be removed and replaced.

3. The sub-base shall be thoroughly rolled or tamped and shall be set just before, if necessary, the concrete is placed, but shall show no pools of water.

10. BLOCKING FOR PRESSURE LINES:

Water pipe installed around curves and at all unsupported changes of direction, all tees, wyes, crosses, plugs and other like fittings, shall be solidly and properly blocked with concrete against solid earth to take the reaction of the main pressure and to prevent lateral movement of the pipe or fitting when under pressure. Concrete for reaction blocking shall have a minimum compressive strength of 3,000 psi at 28 days. The blocking, unless otherwise shown, shall be so placed that the pipe and fitting joints will be accessible for repair. Refer to the Standard Drawings for typical details (Drawing No. W-24). Concrete collars and thrust rods may be required by the City where concrete blocking is inadequate or where the interruption of service is not permissible.

11. FIRE HYDRANT INSTALLATION:

Hydrants shall be set plumb and the hydrant lateral shall have at least 36 inches cover over the pipe. The bottom flange of the hydrant shall be set 1-1/2 inches above the finished ground level. Backfill shall be carefully placed in six (6) inch layers and carefully tamped. Concrete thrust blocks shall be poured at each hydrant tee. The hydrant shall be properly anchored to the hydrant tee by the use of anchoring pipe. Not less than seven (7) cubic feet of crushed or broken stone shall be placed around the base of the hydrant to insure drainage. The interior of the hydrant shall be thoroughly cleaned of all foreign matter prior to installation. After installation, each hydrant and valve shall be inspected in both opened and closed positions to assure that all parts are in satisfactory working condition. Refer to the Standard Drawings for typical details (Drawing Nos. W-37 and W-38). All hydrants shall be marked on the top layer of asphalt of each street by a blue reflective marker. (Astro Optics Corporation TPM-2B or equivalent). The marker shall be set in the middle of the lane nearest to the fire hydrant and shall be made to adhere to the asphalt with the appropriate epoxy-type glue or cement.

12. VALVE INSTALLATION:

A. Valve boxes and covers shall be provided with all valves, shall be of the adjustable slide type, of the length required, and installed as detailed in the Standard Drawings. The valve boxes shall be centered over the operating nut of the valve. (Drawing No. W-6)

B. The markers shall be set opposite the valves in such a location as they would not be destroyed by traffic. The top of the marker should be set about 18 inches above ground.

C. Valve locations shall be marked on the street curb with a saw-cut letter "V". The saw-cut letter "V" shall be painted blue.

13. WATER SERVICE LINE INSTALLATION:

Service line installation shall have a minimum cover of 18 inches. The service line shall be continuous from the water meter to the corporation stop. Refer to typical detail in the Standard Drawings.

14. PRESSURE AND LEAKAGE TESTS:

A. Pressure Test: After pipe has been laid and backfilled, it shall be subjected to a hydrostatic pressure of 200 psi for one (1) hour. Before applying the specified test pressure, all air must be expelled from the line. The City Utility Inspector must witness all pressure tests. Any cracked or defective pipe, fittings, valves, or hydrants discovered during this pressure test, shall be removed and replaced with sound material. The test shall be repeated until satisfactory.

B. Leakage Test:

1. The duration of the leakage test shall be two (2) hours, and during the test, the main or section of the main under test shall be subjected to 150 psi pressure based on the lowest point in the line or section under test and corrected to the elevation of the test gauge. The leakage test shall be performed concurrently with the pressure testing of the water mains.

2. Leakage is defined as the quantity of water to be supplied into the newly laid pipe, or any valved section thereof, after the air has been expelled and the pipe has been filled with water to the 150 psi test pressure. No pipe installation will be accepted until the leakage is less than the number of gallons per hour, as determined by the formula below and by following Table 5-1:

$$L = \frac{ND \sqrt{P}}{7400}$$

L = Allowable leakage in gallons per hour.

N = Number of joints in the section of pipe tested.

D = Nominal diameter of pipe in inches.

P = Average test pressure during the leakage test in pounds per square inch gauge.

3. The following table is based on the above leakage formula. Allowable leakage is shown in gallons per 1,000 feet of pipeline for a two (2) hour pressure test at 150 psi.

Table 5-1 Allowable Leakage During water Test

Pipe Size	Allowable Leakage Per 1000 feet During Test
6	1.1 Gallon
8	1.5 Gallon
10	1.8 Gallon
12	2.2 Gallon

15. FLUSHING AND DISINFECTION:

A. All piping, complete with fittings and appurtenances, shall be flushed until clean and sterilized as specified in AWWA C601 (latest revision) "Disinfecting Water Mains", except that the tablet method, Section 7.3, **shall not be allowed**. The requirements of this paragraph apply equally to new pipe and fittings and to existing pipe-lines into which connections have been made, or which may have been otherwise disturbed to the extent that contamination may have occurred.

B. Chlorine shall be added and a residual of 50 mg/l shall be maintained in the portion of line to be disinfected for a 24-hour period. After 24 hours, a sample shall be taken by the City Utility Inspector and tested at the City Laboratory at the City's Water Treatment Facility (770) 781-2026. The test shall show a residual chlorine level of at least 25 mg/l.

C. When it has been determined that a residual chlorine concentration of 25 mg/l exists after a 24-hour period, the heavy chlorinated water shall be flushed from the water line. After flushing, the chlorine residual shall be less than or equal to 1.0 mg/l.

D. After the water line has been flushed, the City Utility Inspector shall take two (2) samples from the water line. One (1) sample shall be tested and show a chlorine residual less than or equal to 1.0 mg/l. The other sample shall be tested for bacteriologic quality and show the absence of coliform organisms. If chlorine residual tests exceed 1.0 mg/l, the water line must be flushed until chlorine residual is equal to or less than 1.0 mg/l. The chlorine residual must be 1.0 mg/l or less before samples can be taken and tested for bacteriologic quality.

E. The "tablet method" of disinfection, which consists of placing calcium hypochlorite granules or tablets in the water main as it is being installed and then filling the main with potable water when installation is complete, is not allowed.

F. Before the main is chlorinated, it shall be filled to eliminate air pockets and shall be flushed to remove particulates. A flushing velocity of not less than 2.5 feet/second is usually maintained in pipe sizes less than 24 inches in diameter. For

larger diameter mains, an alternative to flushing, such as broom sweeping of the main, is acceptable prior to chlorinating the main.

G. The chlorine solution used for disinfection of water mains shall have a free chlorine residual concentration not less than 25 mg/L. This heavily chlorinated water shall be retained in the main for at least 24 hours, during which time all valves and hydrants shall be operated to ensure disinfection of the appurtenances.

H. After the applicable retention period, the heavily chlorinated water must not be disposed in a manner that will harm the environment. Neutralizing chemicals, such as Sulfur Dioxide, Sodium Bisulfite, Sodium Sulfite or Sodium Thiosulfate can be used to neutralize the chlorine residual remaining in the water to be wasted.

I. Flush all lines until residual is equal to existing system. After final flushing and before the water main is placed into service, water samples shall be collected from the main and tested for microbiological quality in accordance with the Georgia Rules for Safe Drinking Water, Chapter 391-3-5.

NOTE: The highly chlorinated water that is generated during the disinfection of any water line shall not be allowed in any way to enter the City's distribution system. If the City discovers that any person has allowed highly chlorinated water to enter the City's distribution system, the City shall hold that person in violation of the City's Utility Ordinance. In addition, chlorinated water shall not be allowed to enter the City's Municipal Separate Storm Sewer System (MS4). A fine of not less than \$1000 per day shall be levied against those individuals and/or companies who violate these requirements.

12. AS-BUILT DRAWINGS:

As-built drawings shall be submitted to the City of Cumming for every project governed by this book of specifications. The City of Cumming will not permit the issuance of any certificate of occupancy or the approval of any final plat until appropriate as-built drawings are received. This includes both hard copies and electronic copy in AutoCAD format on CD ROM.

SECTION VI: Standard Drawings of Typical Details **Index**

W-1	Valve Location When Water Line is Not Looped Typical Valve Location
W-2	Water Meter Installation--Typical Service Line Installation
W-3	Typical Bedding Details for Water Mains
W-4	Typical Curb & Gutter Installation Details
W-5	Typical Butterfly Valve Installation Details
W-6	Typical Gate Valve Installation Details
W-7	Utility Location Within Right-Of-Way--Subdivision
W-8	Intersection Details Water Mains, Valves, Fire Hydrant--Subdivision
W-9	Intersection Details Water Mains, Valves, Fire Hydrant--GA DOT & County Roads
W-10	PVC Pipe Detector Wire
W-11A	Allowable Trench Widths 3/4" - 2" Service Lines & 2" and Larger Water Mains - CHART
W-11B	Allowable Trench Widths 3/4" - 2" Service Lines & 2" and Larger Water Mains - DRAWING
W-11C	Allowable Trench Widths 3/4" - 2" Service Lines & 2" and Larger Water Mains - NOTES
W-12	Maximum Permissible Joint Deflections
W-13	Mechanical Joint Bolt Usage Chart
W-14	Tapping Sleeve and Valve Installation Details
W-15	Tapping Sleeve Length

W-16	Stub-Out Detail
W-17	Round Connection Detail
W-18	Blow-Off Detail 6" and Larger Mains
W-19	Blow-Off Detail 3/4" - 2" Mains
W-20	Blow-Off Tap Sizes for Flushing
W-21	Jumper Connections
W-22	Pipe Joining Use of Solid Sleeve
W-23	2" Main Extension/Termination--Subdivisions
W-24	Thrust Restraint: Horizontal Block
W-25	Thrust Restraint: Horizontal Block/Support PVC Pipe
W-26	Thrust Restraint: Upward Thrust
W-27	Thrust Restraint: Upward Thrust
W-28	Thrust Restraint: Upward Thrust--Encased
W-29	Thrust Restraint: Downward Thrust
W-30	Thrust Restraint: Concrete Collar
W-31	Thrust Restraint: "Dead Man" Concrete Type
W-32	Thrust Restraint: Horizontal 6", 8", 10", 12" and 14" Mains Type A
W-33	Thrust Restraint: Horizontal 16", 20" and 24" Mains Type A
W-34	Thrust Restraint: Tie-Rod Chart
W-35	Thrust Restraint: Tie-Rod Installation
W-36	Thrust Restraint: Strap and Rod Details
W-37	Fire Hydrant Installation--Subdivision
W-38	Fire Hydrant Installation--GA DOT & County Roads

- W-39 Air Valve Installation
- W-40 Casing/Pipe Support Installation
- W-41 Water System Configuration In Relation To Sidewalks (New Development)
- W-42 1" Line Service Stub Details For Two ¾-Inch Water Meters
- W-43 Service Line Conduit with Locator Wire--Subdivisions Only
- W-44 Meter Locations: ¾" - 2"
- W-45 ¾" - 1" Meter Settings Short and Long Sides
GA DOT and County Roads
- W-46 2" Meter Setting
- W-47 Water System Configuration In Relation To Catch Basins Located On The
Property Line
- W-48 Pavement Cut Repairs Type "A", "B", and "C"
- W-49 Pavement Cut Repairs ¾" - 2" Sleeve Lines
- W-50 Driveway Cut Repairs Concrete, Gravel and Asphalt
- W-51 Sidewalk, Curb and Gutter Repairs
- W-52 Sediment Barrier Erosion Control: Silt Fence
- W-53 Sediment Barrier Erosion Control: Silt Fence Chart
- W-54 Sediment Barrier Erosion Control: Hay Bales
- w-55 Sediment Barrier Erosion Control: Check Dams
- W-56 Cast Iron Locking Meter Boxes For 5/8" X 3/4" Meters
- W-57 Water Meter Box Configuration
- W-58 Stream Crossings
- W-59 6-inch Double Detector Check
- W-60 8-inch Double Detector Check

W-61	1" Line Service Stub Details For One $\frac{3}{4}$ -Inch Water Meter
W-62	Multiple Water Services For Cul-de-sac Lots
W-63	Multiple Water Services From One 1-inch Tap
W-64	Preconstruction List For Water
W-65	Final Plat Check List Part A
W-66	Final Plat Check List Part B
W-67	RPZ Backflow Preveter With Hot Box
W-68	Concrete Encasement Detail
W-69	Materials List Quick Reference Sheet
W-70	Water Notes