

5'-0" MINIMUM FROM EDGE OF
STREAM BANK TO EDGE OF
CONCRETE ENCASEMENT
(TYPICAL)

18" MINIMUM BELOW
STREAM BED

RIPRAP

DUCTILE IRON
CARRIER PIPE

CONCRETE ENCASEMENT
SEE DETAIL S-15

REVISIONS

City of Cumming

Department of Utilities - Distribution and Collection Division

STREAM CROSSING



S-22