


PIPE	A		B				C	D			
SIZE	SIDE CLEARANCE - INCH		DITCH WIDTH - INCH				SHORING WIDTH	CUT REPAIR WIDTH - FEET			
(NOMINAL)	SOIL	ROCK	SOIL		ROCK		(ADDITIONAL - INCH)	SOIL		ROCK	
			MJ	SJ	MJ	SJ		MJ	SJ	MJ	SJ
3/4"-2"	2	6	NA	8	NA	14	AS APPROVED	NA	3.00	NA	3.17
4"	9	12	25	23	27	25	AS APPROVED	4.08	3.92	4.25	4.08
6"	9	12	28	28	30	30	AS APPROVED	4.33	4.33	4.50	4.50
8"	9	12	32	30	34	32	AS APPROVED	4.67	4.50	4.83	4.67
10"	9	12	34	32	36	34	AS APPROVED	4.83	4.67	5.00	4.83
12"	9	12	36	34	38	36	AS APPROVED	5.00	4.83	5.17	5.00
14"	9	14	39	36	41	38	AS APPROVED	5.25	5.00	5.42	5.17
16"	9	14	42	38	44	40	AS APPROVED	5.50	5.17	5.67	5.33
20"	9	14	45	44	47	46	AS APPROVED	5.75	5.67	5.92	5.83
24"	9	14	50	48	52	50	AS APPROVED	6.17	6.00	6.33	6.17
30"	9	18	58	54	60	56	AS APPROVED	6.83	6.50	7.00	6.67
36"	9	18	64	61	66	63	AS APPROVED	7.33	7.08	7.50	7.25
42"	9	18	72	64	74	66	AS APPROVED	8.00	7.33	8.17	7.50
48"	9	18	78	73	80	75	AS APPROVED	8.50	8.08	9.34	8.25

REVISIONS

City of Cumming
 Department of Utilities - Distribution and Collection Division

ALLOWABLE TRENCH WIDTHS 3/4-INCH TO 2-INCH SERVICE LINES AND 2-INCH AND LARGER WATER MAINS - CHART



W-11 A