

## PVC PIPE MINIMUM TAPPING SLEEVE LENGTH

MAIN AND TAP (INCHES NOMINAL)	LENGTH (ALONG RUN)
6 X 6, 6 X 3, 6 X 4, 6 X 2	18"
8 X 2, 8 X 3, 8 X 4, 8 X 6	19"
8 X 8	21"
10 X 2, 10 X 3, 10 X 4, 10 X 6	19"
10 X 8, 10 X 10	23"
12 X 2, 12 X 3, 12 X 5, 12 X 6	19"
12 X 8	21"
12 X 10, 12 X 12	25"

**NOTES:**

**1. ALL TAPPING SLEEVES AND VALVES SHALL BE HYDROSTATICALLY TESTED BEFORE TAP IS MADE. SEE DRAWING W-14 FOR TYPICAL INSTALLATION AND NOTES.**

**2. PERSONNEL INSTALLING TAPPING SLEEVE AND VALVE SHALL FOLLOW MANUFACTURER'S INSTALLATION PROCEDURES AND THE REQUIREMENTS OF THE CITY OF CUMMING DEPARTMENT OF UTILITIES.**

REVISIONS


**City of Cumming**  
 Department of Utilities - Distribution and Collection Division

### TAPPING SLEEVE LENGTH



# W-15