



NOTE:  
 GATE VALVES AND FITTINGS USED IN THIS CONNECTION TO BE SAME SIZE AS EXISTING MAIN WHERE EXISTING MAIN IS 12" OR SMALLER.

REVISIONS

**City of Cumming**  
 Department of Utilities - Distribution and Collection Division



**ROUND CONNECTION DETAIL**

**W-17**