



MINIMUM DIMENSIONS IN FEET FOR CONCRETE COLLAR ON DUCTILE IRON PIPE TO BE USED WITH EMBEDDED DUCTILE IRON RETAINER GLAND.

PIPE SIZE	A	B	C	D	E	VOLUME CU YDS	CONC WT	THRUST
4"	3' - 6"	3' - 0"	1' - 5"	1' - 6"	1' - 0"	0.55	2230	3150
6"	4' - 0"	3' - 0"	2' - 7"	2' - 0"	1' - 0"	1.15	4650	7070
8"	4' - 6"	3' - 0"	3' - 0"	2' - 3"	1' - 3"	1.5	6075	12,570
10"	5' - 2"	3' - 0"	3' - 2"	2' - 7"	1' - 3"	1.81	7330	19,635
12"	5' - 9"	3' - 0"	3' - 8"	2' - 10.5"	1' - 8"	2.34	9475	28,775
14"	6' - 6"	3' - 0"	4' - 0"	3' - 3"	1' - 9"	2.89	11,700	38,490
16"	6' - 9"	3' - 0"	4' - 9"	3' - 3"	2' - 3"	3.56	14,410	50,270

**NOTES:**

1. ALL WATER MAINS GREATER THAN 16" I.D. SHALL BE INDIVIDUALLY CALCULATED BY THE CITY OF CUMMING.
2. SOIL CONDITIONS SHALL BE VERIFIED BY HTE ENGINEER BEFORE THRUST RESTRAINT DESIGN IS IMPLEMENTED.
3. PIPE MUST BE DUCTILE IRON.

**DESIGN DATA:**

1. DIMENSION OF THRUST RESTRAINT IN FEET BASED ON 2000 POUNDS PER SQUARE FOOT SOIL BEARING PRESSURE AND 250 PER SQUARE INCH TEST PRESSURE. ACTUAL INSIDE DIAMETER OF DUCTILE IRON PIPE, CLASS 50, USED AS STANDARD.
2. CONCRETE SHALL BE CLASS A, 3000 PSI.
3. UNDER ADVERSE CONSTRUCTION CONDITIONS, CONCRETE SHALL BE "HIGH EARLY" TYPE.

REVISIONS

**City of Cumming**  
 Department of Utilities - Distribution and Collection Division

**THRUST RESTRAINT**  
**CONCRETE COLLAR**

**W-30**