



- NOTES:**
1. SEE DRAWING W-34 FOR NUMBER AND DIAMETER OF RODS REQUIRED.
 2. NO FLANGED JOINTS ARE TO BE BURIED.
 3. AFTER INSTALLATION, TIE-RODS AND CLAMP ASSEMBLIES SHALL BE CLEANED AND THOROUGHLY COATED WITH ROYSTON LABORATORIES, INC. ROSKOTE PLASTIC NO. A 939 OR KOPPERS CO., INC. BITUMASTIC SUPERSERVICE BLACK OR APPROVED EQUIVALENT.

REVISIONS

City of Cumming
 Department of Utilities - Distribution and Collection Division

**TRHUST RESTRAINT:
TIE ROD INSTALLATION**

W-35