



No. 12 AWG. SOLID COPPER  
WRAPPED AROUND CONDUIT  
(SEE DRWG. W10)

MINIMUM COVER  
FOR CASING IS 3-FT  
SUBDIVISION ROADS ONLY

NOTES

1. CONDUIT LOCATIONS SHALL BE MARKED ON CURBS ON BOTH SIDES OF STREET.
2. INSPECTOR MUST VERIFY PRESENCE AND DEPTH OF CONDUITS.
3. MINIMUM COVER FOR ALL WATER MAINS (6-INCH - 10-INCHES IN DIAMETER) SHALL BE 3.0-FT. FOR ALL WATER MAINS 12-INCHES AND LARGER IN DIAMETER, MINIMUM COVER SHALL BE 4.0-FT.

REVISIONS

**City of Cumming**  
Department of Utilities - Distribution and Collection Division



**SERVICE LINE CONDUIT**  
**WITH LOCATOR WIRE**  
**SUBDIVISIONS ONLY**

W-43