

WATER NOTES:

1. ALL WATER CONSTRUCTION SHALL COMPLY WITH THE MOST CURRENT EDITION OF THE CITY OF CUMMING MANUAL OF TECHNICAL SPECIFICATIONS AND CONSTRUCTION STANDARD DETAILS.
2. NOTIFY THE CITY OF CUMMING UTILITY INSPECTOR AT (770) 781-2025 OR (770) 781-2035 AT LEAST 24-HOURS PRIOR TO EACH PHASE OF CONSTRUCTION AND WHENEVER WORK IS TO BE STOPPED FOR MORE THAN 24-HOURS FOR ANY REASON EXCEPT FOR WEATHER.
3. ALL MATERIALS, INCLUDING BUT NOT LIMITED TO FITTINGS, SHALL BE INSPECTED BY THE CITY OF CUMMING UTILITY INSPECTOR PRIOR TO INSTALLATION.
4. THE PROJECT OWNER OR ENGINEER SHALL BE RESPONSIBLE FOR PROVIDING THE CONTRACTOR WITH AN APPROVED, STAMPED SET OF CONSTRUCTION PLANS PRIOR TO CONSTRUCTION.
5. THE CONTRACTOR SHALL BE RESPONSIBLE FOR MAINTAINING A MARKED-UP SET OF CONSTRUCTION DRAWINGS THAT INCLUDE ALL AS-BUILT CONDITIONS. AS-BUILT OR RECORDED DRAWINGS WILL BE REQUIRED PRIOR TO FINAL APPROVAL AND RELEASE OF THE PROJECT. IN ADDITION, AS-BUILT DRAWINGS IN ELECTRONIC, AUTOCAD FORMAT MUST BE SUBMITTED TO THE DEPARTMENT OF UTILITIES PRIOR TO FINAL APPROVAL AND RELEASE OF THE PROJECT.
6. PROPOSED OR FUTURE SIDEWALKS SHALL NOT BE DESIGNED OR CONSTRUCTED IN A MANNER THAT IN ANY WAY COVERS A WATER MAIN OR WATER METER.
7. NO CONSTRUCTION WORK WILL BE ALLOWED WITHIN THE RIGHT-OF-WAY OF A GEORGIA DEPARTMENT OF TRANSPORTATION ROADWAY OR JOB SITE WITHOUT AN APPROVED PERMIT AND WITHOUT 48-HOURS PRIOR NOTICE TO THE CITY OF CUMMING UTILITY INSPECTOR.
8. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING A UTILITY PERMIT FROM THE FORSYTH COUNTY DEPARTMENT OF ENGINEERING PRIOR TO THE CONSTRUCTION OF ANY UTILITY WITHIN THE RIGHT-OF-WAY OF A COUNTY MAINTAINED ROAD. (770) 781-2165.
9. DEVELOPERS, CONTRACTOR, OWNERS, ETC. REQUESTING WATER SERVICE AT ELEVATIONS IN EXCESS OF 1280 FEET (MSL) SHALL BE RESPONSIBLE FOR DESIGNING AND CONSTRUCTING A WATER BOOSTER PUMPING SYSTEM WHICH MEETS THE APPROVAL OF THE CITY OF CUMMING UTILITIES ENGINEER.

REVISIONS

City of Cumming

Department of Utilities - Distribution and Collection Division

WATER NOTES



W-70