



NOTES:

1. Before any utility is installed, the required width of the roadway shall be rough graded and all concrete curbing shall be set at final grades.
2. In general, the water mains should be installed first. Following water main installation, utilities are to be installed in this order: 1) electric power 2) gas 3) telephone 4) cable T.V. All utilities shall be installed prior to paving.
3. On those subdivision streets where no curb is called for in the plans, measurements shall be from the edge of pavement.
4. At cul-de-sacs, all dimensions shall remain identical to standard street spacing, except that gas will be 3.0 FT and telephone will not be looped.
5. Each utility shall be responsible for repairs of any damage they create to other utilities and to the street improvements within the right-of-way.
6. Minimum cover for all water mains (within subdivision road ROWs) that are 6 inches - 10 inches in diameter shall be 3.0 FT. For all water mains 12 inches and larger in diameter (within subdivision road ROWs), minimum cover shall be 4.0 FT. Minimum cover for all water mains located in the ROW of County or DOT Roads shall be 4.0 FT

REVISIONS

City of Cumming
 Department of Utilities - Distribution and Collection Division
**UTILITY LOCATION WITHIN THE
 RIGHT-OF-WAY OF SUBDIVISIONS**

