



SECTION F-F

WET WELL SHALL MEET THE REQUIREMENTS OF ASTM C478

WET WELL DIMENSIONS AND GEOMETRY SHOWN AS PER FOLEY PRODUCTS CO.
PHONE: (770) 251-0296

SUBMIT WET WELL AND VALVE BOX SHOP DRAWINGS TO THE ENGINEER FOR APPROVAL BEFORE PURCHASING.

INSIDE WALLS OF WET WELL, VALVE BOX, AND PIPES IN SIDE WET WELL SHALL BE COATED WITH A TWO PART EPOXY, BY INDRON RUFF STUFF 2100 COAL TAR EPOXY OR TNEMEC HI-BUILD TNEME TAR 46H-413.



LATEST REVISION

07/14/2017

CITY OF CUMMING

DEPARTMENT OF UTILITIES

WET WELL CONFIGURATION (EXAMPLE ONLY)

DETAIL NUMBER:

PS-18

SCALE: NOT TO SCALE