



1. BEFORE ANY UTILITY IS INSTALLED, REQUIRED WIDTH OF THE ROADWAY SHALL BE ROUGH GRADED AND ALL CONCRETE CURBING SET AT FINAL GRADES.
2. IN GENERAL SEWER MAINS, STORM, WATER SHOULD BE INSTALLED FIRST. AFTER SEWER INSTALLATION, UTILITIES ARE TO BE INSTALLED IN THE FOLLOWING ORDER: 1) ELECTRIC POWER, 2) GAS, 3) TELEPHONE, AND 4) CABLE TV. ALL UTILITIES TO BE INSTALLED PRIOR TO PAVING.
3. ON SUBDIVISION STREETS WHERE NO CURB IS CALLED FOR ON THE PLANS, MEASUREMENTS SHALL BE FROM EDGE OF PAVEMENT.
4. AT CUL-DE-SAC, ALL DIMENSIONS SHALL REMAIN IDENTICAL TO STANDARD STREET SPACING, EXCEPT THAT GAS SHALL HAVE 3'-0" OF COVER AND TELEPHONE SHALL NOT BE LOOPED.
5. EACH UTILITY SHALL BE RESPONSIBLE FOR REPAIRS OF ANY DAMAGE THEY CREATE TO OTHER UTILITIES OR TO THE STREET IMPROVEMENTS WITHIN THE RIGHT OF WAY.
6. MINIMUM COVER SHALL BE 3'-0" FOR ALL WATER MAINS 6" THROUGH 10" DIAMETER AND 4'-0" COVER FOR MAINS 12" AND LARGER.



LATEST REVISION

07/14/2017

CITY OF CUMMING

DEPARTMENT OF UTILITIES

UTILITY LOCATION WITHIN THE RIGHT-OF-WAY - SUBDIVISIONS

DETAIL NUMBER:

S-1

SCALE: NOT TO SCALE