


NOTES:

1. VENTED CONNECTION TO MANHOLE TO CONSIST OF STEEL PIPE AND 3000 PSI CLASS "B" CONCRETE COMPLETE
2. PIPE TO BE PAINTED WITH 2 COATS OF BITUMINOUS ENAMEL
3. STEEL PIPE SCHEDULE 80:
 - 3" DIA. FOR MANHOLES LESS THAN 6' DIA
 - 4" DIA. FOR MANHOLES 6' - 10' DIA
 - 5" DIA FOR MANHOLES 10' - 15' DIA
 - 6" DIA. FOR MANHOLES LARGER THAN 15' DIA
4. HEIGHT OF STACK SHALL BE SET ABOVE THE 100 YR FLOOD ELEVATION PLUS 2 FEET.

 <p>CUMMING UTILITIES</p>	<p>CITY OF CUMMING</p> <p>DEPARTMENT OF UTILITIES</p> <p>VENTED MANHOLE</p>	<p>DETAIL NUMBER:</p> <p>S-11</p>
<p>LATEST REVISION</p> <p>07/14/2017</p>		<p>SCALE: NOT TO SCALE</p>