


MARKER BALL REFERENCE		
TAG NO.	DESCRIPTION	DEPTH
XXX-XXX-XXX	SIZE, MATERIAL, FITTING	DEPTH OF MARKER BALL TO TOP OF PIPE

**NOTES:**

1. LOCATOR BALL TO BE CONSTRUCTED AT BENDS, AND AT 200-FOOT INTERVAL ON STRAIGHT PIPE.
  2. MARKER BALLS SHALL BE 3M DYNATEL SERIES EMS ID BALL MARKERS MODEL NUMBER 1424-XR/ID FOR SEWER.
- LOCATOR SHALL BE 3M DYNATEL 2250M-ID-UU-3W-RT.



**CUMMING UTILITIES**

LATEST REVISION

07/14/2017

**CITY OF CUMMING**

DEPARTMENT OF UTILITIES

**MARKER BALL DETAIL**

DETAIL NUMBER:

**S-27**

SCALE: NOT TO SCALE