



**NOTE:**  
 MANHOLE DESIGN SPECIFICATION CONFORMS TO: PRECAST REINFORCED CONCRETE MANHOLE SECTIONS A.S.T.M. DESIGNATION C-478 LATEST REVISION. CONCRETE COMPRESSIVE STRENGTH 4000 psi @ 28 DAYS.



# CITY OF CUMMING

DEPARTMENT OF UTILITIES

## SHALLOW MANHOLE

DETAIL NUMBER:

# S-9

LATEST REVISION

07/14/2017

SCALE: NOT TO SCALE