



- NOTES**
1. ALL PERMANENT BLOW-OFF INSTALLATIONS MUST BE AUTHORIZED BY CITY PRIOR TO INSTALLATION.
  2. 90 DEGREE BEND AND EXTENSION PIECE TO BE USED ON PERMANENT RUNNING BLOW-OFF.
  3. BLOW OFF TAP SIZES SHALL BE IN ACCORDANCE WITH AWWA M4 WATER FLUORIDATION (CURRENT EDITION).



# CITY OF CUMMING

DEPARTMENT OF UTILITIES

## BLOW OFF VALVE DETAIL

3/4-INCH TO 2-INCH

DETAIL NUMBER:

# W-10B

SCALE: NOT TO SCALE

LATEST REVISION

07/14/2017