


- NOTES:**
1. FOR ALL WATER MAINS IN COUNTY, STATE, OR FEDERAL R/W'S - MIN. COVER SHALL BE 3' - 0".
  2. IF REGULAR TEE USED, MIN. NIPPLE LENGTH SHALL BE 12"
  3. THE FIRE DEPT REQUIRES HYDRANT TO BE LOCATED WITHIN 3 FEET OF THE CURB.



**CITY OF CUMMING**

DEPARTMENT OF UTILITIES

**FIRE HYDRANT INSTALLATION**

**SUBDIVISIONS**

DETAIL NUMBER:

**W-20**

SCALE: NOT TO SCALE

LATEST REVISION

07/14/2017