



18" GRASS STRIP  
REQUIRED  
BETWEEN  
SIDEWALK AND  
BACK OF CURB

- NOTES:**
1. IF WATER MAIN MUST BE DEFLECTED AROUND A CATCH BASIN OR STORM SEWER, DEFLECTED PORTION MUST BE 3 LENGTHS OF DIP.
  2. WATER MAINS CROSSING STORM SEWER LINES MUST BE DIP.
  3. ALL WATER METERS MARKED AT CURB "W".



LATEST REVISION  
07/14/2017

# CITY OF CUMMING

DEPARTMENT OF UTILITIES

## WATER MAIN AND SERVICE LINE LOCATIONS

DETAIL NUMBER:

# W-23A

SCALE: NOT TO SCALE