



NOTES:

1. IN THE EVENT CASING IS NOT PRESENT ON LONG SIDE LOT, BORING SHALL BE PERMITTED.
2. NO PAVEMENT CUTS WILL BE PERMITTED WITHOUT APPROVAL OF THE CITY WATER INSPECTOR AND THE (CITY, COUNTY, OR STATE) ROAD ENGINEER.
3. 3-4 FT MIN. COVER FOR SUBDIVISION ROADS. STATE AND COUNTY ROADS, MIN. 4 FT COVER.
4. ALL CUTS IN PAVEMENT SHALL BE REPAIRED IN ACCORDANCE WITH GA D.O.T. OR FORSYTH CO. STANDARDS. SEE PAVEMENT CUT REPAIR STANDARD DETAIL.
5. METERS SHALL NOT BE OFFSET Laterally FROM TAP ON WATER MAIN, SET DIRECTLY OPPOSITE TAP LOCATION.
6. FOR SERVICE LINE RELOCATIONS TO NEW MAINS COPPER TUBING TYPE "K" SHALL BE REQUIRED.



LATEST REVISION

07/14/2017

CITY OF CUMMING

DEPARTMENT OF UTILITIES

**1-INCH METER LOCATION
GA DOT & COUNTY ROADS**

DETAIL NUMBER:

W-23C

SCALE: NOT TO SCALE