



NOTES:

1. CONDUIT LOCATIONS SHALL BE MARKED "W" AT CURBS ON EACH SIDE OF STREET.
2. INSPECTOR SHALL VERIFY PRESENCE AND DEPTH OF CONDUITS.
3. MINIMUM COVER FOR ALL WATER MAINS 6 -10 INCH DIAMETER SHALL BE 3 FT. 12-INCH AND LARGER SHALL BE 4 FT.



LATEST REVISION

07/14/2017

CITY OF CUMMING

DEPARTMENT OF UTILITIES

SERVICE LINE CONDUIT

SUBDIVISIONS

DETAIL NUMBER:

W-24

SCALE: NOT TO SCALE