


**VALVE STEM EXTENSION
DETAIL**

- NOTES:**
1. ALL GATE VALVES SHALL HAVE A VALVE BOX.
 2. VALVE STEM REQUIRED ON INSTALLATIONS OVER 4' OF DEPTH, BROUGHT TO WITHIN 2' OF FINISHED GRADE.
 3. VALVE EXTENSION TO HAVE SET SCREWS.



CUMMING UTILITIES

LATEST REVISION

07/14/2017

CITY OF CUMMING

DEPARTMENT OF UTILITIES

BUTTERFLY VALVE INSTALLATION

DETAIL - 12" OR LARGER

DETAIL NUMBER:

W-5

SCALE: NOT TO SCALE